

Lead and Copper Rule Results
November, 2018

Year	Lead 90 th Percentile, mg/L	Copper 90 th Percentile, mg/L
2018	0.004	0.04
2015	0.002	0.09
2012	0.002	0.49
2009	0.003	0.57
2008	0.008	0.52
2007	0.003	0.45
2006	0.004	0.58
2005	0.005	0.82
1992	< 0.01	4.55

Notes:

- 1.) 90th Percentile Action limits per Mass DEP:
 - a.) 0.015 mg/L for Lead
 - b.) 1.300 mg/L for Copper
- 2.) In 2009, MassDEP approved a request from Wareham Water for monitoring lead and copper every three years per the LCR due to the low levels of Lead and Copper monitored at the customer tap.